

Installer Performance


Gary Ellars



Installer Performance

Online Year

Installer



Online Month	Interconnections with Errors	Error Free Interconnections	Total Installations	% Error Free Installations
Jan	557	1223	1780	68.71%
Feb	472	1086	1558	69.70%
Mar	458	1252	1710	73.22%
Apr	415	1215	1630	74.54%
May	323	961	1284	74.84%
Jun	379	1434	1813	79.10%
Jul	331	1162	1493	77.83%
Aug	538	1311	1849	70.90%
Sep	516	830	1346	61.66%
Oct	644	1226	1870	65.56%
Nov	518	994	1512	65.74%
Dec	501	1041	1542	67.51%
Total	5652	13735	19387	70.85%

Error Type	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	Total
Clearance	49	32	55	35	27	47	50	52	21	36	36	23	463
Disclaimer	68	54	50	23	19	27	31	30	7	25	13	19	366
Executed Contract	64	46	45	37	22	40	46	33	18	28	23	28	430
Meter Set Failed	91	76	94	121	112	99	92	139	117	124	120	137	1,322
One Line Diagram		1		1	2	1						2	7
Site Plan	306	285	290	318	203	239	196	392	445	530	436	425	4,065
Three Line Diagram	387	338	327	341	235	270	219	435	466	540	429	465	4,452
Total	965	832	861	876	620	723	634	1,081	1,074	1,283	1,057	1,099	11,105

Resources

Visit our one-stop interconnection page at aps.com/dg, where you will find the following helpful resources and more.

[APS Interconnection Requirements Manual \(IRM\)](#)

[APS Electric Service Requirements Manual \(ERSM\)](#)

[Diagram Checklist](#)

[Example Equipment Tags](#)

Questions?

Contact us:

- Email: Renewables@aps.com

- Blanca Moreno – Supervisor, Product and Program Implementation Team
 - Blanca.Moreno@aps.com
 - Phone: (602) 250-4113

- Usama Shami – Installer Liaison
 - Usama.Shami@aps.com
 - Phone: (602) 250-2563