

**ELECTRIC METER SHOP**  
**SERVICE ENTRANCE REPORT/CHECKLIST**

ADDRESS \_\_\_\_\_ TOWN \_\_\_\_\_  
 CUSTOMER \_\_\_\_\_ AREA \_\_\_\_\_

PRINTS RCV'D \_\_\_\_\_ PRINTS APPRV'D \_\_\_\_\_ CSP \_\_\_\_\_ MAN# \_\_\_\_\_  
 SES MFG \_\_\_\_\_ VOLTS \_\_\_\_\_ / \_\_\_\_\_ PHASE \_\_\_\_\_ WIRE \_\_\_\_\_ AIC \_\_\_\_\_  
 SES SIZE \_\_\_\_\_ MULTI MTR \_\_\_\_\_ #CT MTRS \_\_\_\_\_ #SC MTRS \_\_\_\_\_  
 IN/OUTDOOR \_\_\_\_\_ OH/UG \_\_\_\_\_ COMM/RES \_\_\_\_\_ CONN LD \_\_\_\_\_ DEM \_\_\_\_\_  
 FREE STANDIN/WALL MOUNT \_\_\_\_\_ PULL BOX \_\_\_\_\_ GUTTER \_\_\_\_\_ LANDINGS \_\_\_\_\_

CONTRACTOR \_\_\_\_\_ PHONE # \_\_\_\_\_

TRANSFORMER-RATED GENERAL	RESIDENTIAL 400A ALL-IN-ONE	COMMERCIAL SAFETY-SOCKET
_____ METER LOCATION 301.5 _____ LOCK BOX LOCATION 301.10 _____ METER ROOMS 301.9 _____ WORK SPACE 301.7/NEC 110-16 _____ CEMENT PAD 304.5 _____ ANCHORED 302.8 _____ METER ID. ( ADDRESS ) 302.1 _____ MFG. ID. NEC I10-21/302.11 _____ SES SIZE 201.1/201.2 _____ MAIN DISC AIC. 302.3/NEC 230-65 _____ GRD. ELECTRODE 700.2/NEC 250-81 _____ GRD./BOND BUSS CONN. 705.5 _____ MAIN BOND JMP. 701.1/705.0 _____ NEUTRAL DISC. 705.5 _____ RISER BOND 700.3 _____ NIPPLE BOND 700.3 _____ GUTTER BOND 700.3 _____ PULL SECT. BOND 700.3 _____ PULL SECT DIM. 1100-345 _____ # OF LANDINGS 1100-347 _____ LANDING HEIGHT 1100-345 _____ CT. COMPT. DIM. 1100-319 TO 324 _____ NEUTRAL BUSS 705.0 _____ HIGH LEG MARKED 304.3 _____ ALSTAN PLATING 1100-300 M 2 _____ POTENTIAL SCREWS IN BUSS _____ SEALING PROVISIONS 300.3 _____ METER DOORS HINGED 1100-332 _____ DOORS OPEN 90° 1100-332 & 354 _____ CT. METER SOCKET 304.2-1 _____ TEST SWITCH DRILLED/TAPPED _____ METER HEIGHT 302.2 _____ VENTILATION 1100-300 L _____ POINT OF ATTACHMENT 400.1 _____ OH. RISER LEAD LENGTH 401.6	_____ APPROVED CAN ( SEE LIST ) _____ SECURED IN PLACE 302.5 _____ RISER SIZE 501.1-1 _____ RISER BOND 700.3 _____ RISER STRAP 501.3 _____ GRD ELECTRODE 700.2 _____ GRD/BOND BUSS CONN 705.5 _____ MAIN BOND JMP. 701.0/705.0 _____ METER HEIGHT 302.2 _____ MAIN DISC AIC 302.3/NEC 230-65  <hr/> <p style="text-align: center;"><b>MULTI-PAKS</b></p> <hr/> _____ MAIN DISC POS. 302.3/230-71a _____ MAIN DISC AIC 302.3/NEC 230-65 _____ DISCONNECTS 301.14 _____ TEST BLOCKS 1100-304 & 305 _____ NEUTRAL TEASER 303.8 _____ CROSS BUSS BARRIERS 300.2 _____ NETWORK SERVICE 303.8 _____ METER SOCKETS 303.3/303.8 _____ METER HEIGHT 302.2 _____ METER ID 302.1	_____ DIMENSIONS 1100-304 & 305 _____ SECURED IN PLACE 302.5 _____ RISER SIZE 501.1-2/501.1-3 _____ RISER BOND 700.3 _____ RISER STRAP 501 3 _____ NIPPLE BOND 700.3 _____ MAIN DISC AIC 302.3/NEC 230-65 _____ GRD ELECTRODE 700.2 _____ GRD/BOND BUSS CONN 705.5 _____ MAIN BOND JMP 701.0705.0 _____ NEUTRAL TEASER 303.8 _____ LINE/LOAD CORR. 1100-304&5 _____ LINE/LOAD LABELS 303.8 _____ LINE/LOAD BARR. 303.8 _____ METERED/UNMETERED 300.2 _____ TEST BLOCKS 303.6 _____ HIGH LEG RIGHT 303.7 _____ METER SOCKET 303.3/303.8 _____ METER HEIGHT 302.2