

## ESRM Revisions – May 15, 2024

---

Section	Revision
300, 301.8-1, -2, -3	Clarified barrier post, working space, and escape route requirements for service equipment configurations. Deleted 301.8-3.
300, 301.15-3	Deleted the text at the end of 301.15-3 that incorrectly duplicates the text in the first paragraph of ESRM 301.16.
300, 304.5-1.0	Clarified working space and escape route requirements for outdoor service entrance section pads. Added cross-reference to 301.8 for barrier post placement requirements. Added cross-reference to ESRM 1000 for medium voltage concrete pad working space requirements.
500, 502.8, Fig. 3	Changed 502.8 heading to Service Conduits Under Foundation and clarified spacing between spacers in typical duct installation is 6 feet.
1100, 1101.1	Delete the drawings 1101.1, "Low-Profile Switchboard".
1100, EUSERC DWG 309	Delete the drawings EUSERC 309, Sheets 1 & 2 "Commercial Fixed Top Service Pedestals 0-200 Amperes, 0-600 Volts".

## ESRM Revisions – November 15, 2023

---

Section	Revision
300, 301.2-1	Corrected the Note 4 incomplete sentence to state "IT IS THE CUSTOMER'S RESPONSIBILITY TO INSTALL CONDUIT AND WIRING BETWEEN THE METER LOCATION AND THE POINT OF ATTACHMENT."
300, 306.0	Deleted the SES riser sizes specified in Note 8 because the information is correctly specified in ESRM 501.1-3.
400, 401.9	Added MIN to the 18" dimension ("18" MIN") describing the unbraced minimum height above the roof for the service drop conduit point-of-attachment.
1000, 1000.1.C	Clarified "customers must notify APS Representative prior to implementing any proposed protective device changes at any time throughout the lifetime of the facilities."

## ESRM Revisions – May 15, 2023

---

Section	Revision
300, 301.2-1	Clarify metering service location identification requirements.

## ESRM Revisions – November 15, 2022

---

Section	Revision
300, 303.6-1	Added additional guidance.
300, 304.5-1	Added to note 5 for SES pad details and note reference added to Detail 2.
300, 304.6	Added note 5.
300, 306.0	Section Header name updated.
300, 306.0	Clarified Note 13.
400, 402.2	Clarified Customer Provided and Customer Owned wood poles.
500, 506.8-1	Added details to note 7.
900, 900.6	Added note 8.
900, 900.7	Added note 6.
1300, 1301.2-1	Clarity on letter height requirements.

## ESRM Revisions – May 15, 2022

---

Section	Revision
100, 104.11	Added cross-reference to the APS Interconnection Requirements Manual for distributed Generation requirements at <a href="https://aps.com/dg">aps.com/dg</a> .
300, 302.1	Added cross-reference to the APS Interconnection Requirements Manual for all interconnect label requirements at <a href="https://aps.com/dg">aps.com/dg</a> .
700, 701.0, Notes 2 & 3	Clarified Note 2 is for sizing conductor used for bonding unfused nipples and equipment. Clarified Note 3 is for sizing main bonding jumper, system bonding jumpers, and supply-side bonding jumpers from equipment grounding bus to neutral bus, per NEC. Corrected NEC 250.66 to NEC 250.102(C)(1) in Column 3 heading.

## ESRM Revisions – March 02, 2022

---

Section	Revision
300, B	Changed 302.13 section description to "Reserved".
302.13	Removed obsolete text, changed 302.13 to "Reserved"
303.1	Removed item 3. No longer applicable.

# ESRM Revisions – January 27, 2022

---

Section	Revision
100, B	Inserted new 102.29 & 102.30 definitions.
100, C	Add 104.9 & 104.10 definitions.
100, 102.7	Add 'Generator' to clarify ESRM 102.7 heading.
100, 102.29	Add 'Switchboard' definition.
100, 102.30	Add 'Switchgear' definition.
100, 104.11-1	Update ANSI Z535.1-1998 to newer ANSI Z535.1-2011 version, & Grammatical errors corrected.
100, 104.11-2	Clarify customer rack-out breakers do not meet visual open requirements, and add placard/warning label requirements.
200, A	Clarify Primary Service (medium voltage range), (601V to 15kV).
200, 201.6	Clarify Primary Service, medium voltage range (601V to 15kV).
300, A	Add Equipment Working Space and Escape Route & Alternate Escape Route.
300, B	Update Service Section to Service Entrance Section.
300, C	Update Outdoor Service Entrance Section titles, add Outdoor Service Entrance Section Pads in Remote Locations with No Access to Water, & Indoor Service Entrance Section Housekeeping Pads.
300, 301.7	Clarify notes for working, clearance, and escape route requirements and updated detail.
300, 301.8, -1 to -3	Clarify barrier post, escape route, and service equipment requirements and added supporting details.
300, 301.15	Update Figures 3 & 4 and add Figures 5 & 6 to clarify the separation Requirements between meters and other utility meters/fuel sources.
300, 302.3-1, 302.9	Wording change switchgear to switchboard.
300, 302.11	Change service section to service entrance section.
300, 302.12	Clarify customer drawing submittal requirements per ESRM 302.9.
300, 304.5, -1 to -3	Clarify escape route, barrier post & equipment pad requirements and add detail and notes for pads where no access to water.
300, 304.6	Add 'Housekeeping Pads' to clarify ESRM 304.6 heading.
800, 800.4	Delete ESRM 800.4.
1000, A	Clarify heading with added text 601V-15V, wording change to 1000.4 from switchboard to switchgear.
1000, 1000.0	Change switchboard to switchgear.
1000, 1000.1	Update voltage for note B to 12.47kV.
1000, 1000.2	Change switchboard to switchgear.
1000, 1000.7	Change switchboard to switchgear.
1000, 1000.9	Change switchboard to switchgear.
1000, 1000.15	Change switchboard to switchgear.
1100, C	Add 407/APS addendum to EUSERC.
1100, 1100.2	Clarify customer drawing submittal requirements per ESRM 302.9.
1100, 407/APS	Clarify 15KV CT designs require 2-bolt, 22-inch between 0 & 1200 Amps.
1300, 1301.2	Clarify high rise APS meters are acceptable at the main SES location.
1400, A	Add sections 1400.3, 1400.3-1, 1400.3-2
1400, 1400.3, -1 & -2	Add new ESRM 1400, 1400-1 & -2 equipment accessibility requirements.

## ESRM Revisions – May 10, 2021

---

Section	Revision
<b>200</b> , 201.2	Added 1200A limitation for SESs greater than 600V.
<b>300</b> , 301.8	Clarified SES concrete pad requirements.
300, 301.15	Added note 4 to clarify 48-inch minimum separation to gas stub out.
300, 302.3-1	Added service disconnect allowable ampacity requirements.
300, 302.9	Updated approval requirements for metering in service equipment.
300, 304.5, 304.5-1 & -2	Clarified SES concrete pad requirements.
300, 304.6	Update note 1 for not greater than 2-1/2 inches housekeeping pad.
<b>400</b> , 401.1	Adding missing note 4 regarding 10 ft. rule.
400, 401.7	Clarified OH service conductor 5 ft. radial clearance.
400, 402.3	Updated notes to clarify pole wrap and steel pole requirements.
<b>600</b> , 602.1-1, 2 & 3	Updated trench figures.
<b>1000</b> , 1000.2-1	Added 1200A limitation for SESs greater than 600V
1000, 1000.3	Clarified manufacturer drawings for approval submittal requirements.
<b>1100</b> , 305	Clarified voltage range is 0 to 600V (not 0 to 800V).
1100, 401/APS	Added notes 7 (1200A SES limitation) and 8 (reference to ESRM 1000.4).
<b>1400</b>	New section 1400 for vehicle approach requirements near APS equipment.

## ESRM Revisions – February 20, 2019

---

Section	Revision
100, 104.1	Added missing text back into manual regarding underground riser.
<b>100</b> , 102.19-5	Added missing text back into ESRM regarding customer-owned UG conduits.
100, 104.1	Added missing text back into manual regarding underground riser.
100, 104.7.1	Harmonic Study Policy with 08/31/17 revision date.
<b>200</b> , 200.2-2	Added missing text regarding upgrading the service.
200, 201.3	Added missing text regarding maximum single phase motor size is 25 HP.
200, 201.7	Paragraph added on Service Voltage Ranges.
200, 201.8	Paragraphs added on Power Quality Investigation.
<b>300</b> , 301.4	Added clarification to note 3 regarding permanent ID tagging.
300, 301.6	Added Note to bottom of paragraph regarding unacceptable panel locations.
300, 301.7	Added note 2 regarding workspace requirements.
300, 301.9	Added to meter room requirements regarding access to interior of building.
300, 301.9	Clarified requirement for meter closets.
300, 301.11 & 301.11-1	Clarified requirement for meter closets.
300, 301.15-1, 2, & 3	New requirements for electric meter clearance to fuel sources.
300, 302.14	Updated meter types used on APS system.
<b>400</b> , 400.1	Added missing note to bottom of paragraph regarding attachment tensions.
400, 401.1	Deleted unnecessary note 4 and re-numbered.
<b>500</b> , multiple locations	Clarified UG conduit is customer-owned.
500, 501.1	Clarified UG riser sizes are minimum sizes required.
<b>800</b> , entire section	Updated multiple fault current tables.
<b>900</b> , 900.1	Clarified in note 6 that disconnects "simultaneously" open all conductors.
<b>1100</b> , entire section	Added updated EUSERC drawings and updated APS addendums.