

Date Reviewed	Manufacturer	Model	Amps	Notes	Viewing Window
5/1/2024	Square D	D323NRB	100	Approved	
	Eaton	DG223NRB	100	Approved	
	Square D	D324NRB	200	Approved	
6/5/2024	Siemens	HF365JWA	400	Approved for single phase use only.	
	Square D	VHU363	100	Approved	
7/3/2024	Eaton	DH363NRKV	100	Approved for single phase use only.	
	Eaton	DH363NDKW-0APS	100	Approved for single phase use only.	Yes
8/22/2024	Square D	VHU364R	200	Approved for single phase use only.	
9/4/2024	Eaton	DH362NDKW-00LL	60	Approved	Yes
	Eaton	DH364NDKW-00LL	200	Approved	Yes
	Eaton	DG222NRB	60	Approved	
11/6/2024	Square D	H324NRB	200	Approved for single phase use only.	
	Siemens	GF-221NRA	30	Approved. Service Barrier shall not be used	
	Siemens	GF-222NRA	60	Approved. Service Barrier shall not be used	
4/2/2025	Schneider	VH363RB	100	Approved	Yes
6/4/2025	Siemens	GNF323RA	100	Approved	
	ABB	THN3365ARVW	400	Approved	
	ABB	THF3365ARVW	400	Approved for single phase use only.	
7/2/2025	Eaton	DG221NRB	30	Approved	
	Eaton	DH363NDK	100	Approved	
8/6/2025	Eaton	DG224URKV	200	Approved	
	Eaton	DG224FRKV	200	Approved	
	Eaton	DG224NRKV	200	Approved	
	Siemens	GF223NRA	100	Approved	

Date Reviewed	Manufacturer	Model	Amps
5/1/2024	Siemens	HNF364R	200 Failed
6/5/2024	Siemens	HF364JW	200 Failed
	Siemens	HF324NR	200 Failed
7/3/2024	Milbank	U7490-XL	125 Failed
9/4/2024	Midwest	M281C1	Failed
12/4/2024	Square D	VH364NR	200 Failed
1/8/2025	Siemens	HF364NR	Failed
	Siemens	HNF364R	Failed
	Siemens	HF366RA	600 Failed
4/2/2025	Sqaure D	H366NR	600 Failed
	Siemens	GF324NR	200 Failed
6/4/2025	Siemens	GF324NRA	200 Failed
	Eaton	DH366NRKV	600 Failed
7/2/2025	Eaton	DH224NRK	200 Failed
	Eaton	DG224FRK	200 Failed
	Eaton	DG224URK	200 Failed