

Date Reviewed	Manufacturer	Model	Amps	Phasing	Notes	Viewing Window
5/1/2024	Square D	D323NRB	100		Approved	
	Eaton	DG223NRB	100		Approved	
	Square D	D324NRB	200		Approved	
6/5/2024	Siemens	HF365JWA	400		Approved for single phase use only.	
	Square D	VHU363	100		Approved	
7/3/2024	Eaton	DH363NRKV	100		Approved for single phase use only.	
	Eaton	DH363NDKW-0APS	100		Approved for single phase use only.	Yes
8/22/2024	Square D	VHU364R	200		Approved for single phase use only.	
9/4/2024	Eaton	DH362NDKW-00LL	60		Approved	Yes
	Eaton	DH364NDKW-00LL	200		Approved	Yes
	Eaton	DG222NRB	60		Approved	
11/6/2024	Square D	H324NRB	200		Approved for single phase use only.	
	Siemens	GF-221NRA	30		Approved. Service Barrier shall not be used	
	Siemens	GF-222NRA	60		Approved. Service Barrier shall not be used	
4/2/2025	Schneider	VH363RB	100		Approved	Yes

Date Reviewed	Manufacturer	Model	Amps	Phasing
5/1/2024	Siemens	HNF364R	200	3 Failed
6/5/2024	Siemens	HF364JW	200	Failed
	Siemens	HF324NR	200	Failed
7/3/2024	Milbank	U7490-XL	125	Failed
9/4/2024	Midwest	M281C1		Failed
12/4/2024	Square D	VH364NR	200	Failed: Viewing window does not clearly show air gap
1/8/2025	Siemens	HF364NR		Failed
	Siemens	HNF364R		Failed
	Siemens	HF366RA	600	Failed
4/2/2025	Sqaure D	H366NR	600	Failed
	Siemens	GF324NR	200	Failed