

Date Reviewed	Manufacturer	Model	Amps	pole	Voltage	Comments
5/1/2024	Square D	D323NRB	100		240	Fused. APPROVED.
	Eaton	DG223NRB	100		240	Fused. APPROVED.
	Square D	D324NRB	200		200	Fused. APPROVED.
6/5/2024	Siemens	HF365JWA	400	3		Fused (2 reviewed). APPROVED.
	Square D	VHU363	100			Unfused. APPROVED.

Date Reviewed	Manufacturer	Model	Amps	Comments
5/1/2024	Siemens	HNF364R	200	Non-fused, Non visible open due to red arc shield. DOES NOT PASS.
6/5/2024	Siemens	HF364JW	200	visual open and window low (viewing window option for HF324NR) DOES NOT PASS.
	Siemens	HF324NR	200	visual open and window low. No viewing window. DOES NOT PASS.