

FOUR CORNERS POWER PLANT COMBINED WASTE TREATMENT POND

Periodic Inflow Design Flood Control System Plan

October 2021
AECOM Project 60664563

Prepared for:

Arizona Public Service
400 North 5th Street
Phoenix, AZ 85004

Prepared by:

AECOM
7720 North 16th Street, Suite 100
Phoenix, AZ 85020
aecom.com

Table of Contents

1.	Introduction	1
2.	Methodology	1
3.	Applicability of 2016 Plan Hydrologic Design Basis	2
4.	2016 Plan – Review by Section	3
4.1	“§257.82 Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”	3
4.2	“Overview”	3
4.3	“§257.82 (a)(1)(2)(3) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”	4
4.4	“§257.82 (b) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”	4
4.5	“§257.82 (c) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”	4
4.6	“§257.82 (d) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”	4
5.	Recommended Additional Technical Investigations or Evaluations	5
6.	Conclusion	5
7.	Limitations	5
8.	Certification Statement	6

Attachment

Attachment A: AECOM, 2016, *Four Corners Power Plant, Combined Waste Treatment Pond, Inflow Design Flood Control System Plan, FC_InflowFlood_012_20161017*, August 31, 2016.

1. Introduction

This Periodic Inflow Design Flood Control System Plan for the Combined Waste Treatment Pond at Four Corners Power Plant, operated by Arizona Public Service (APS), has been prepared in accordance with the requirements of Title 40 of the Code of Federal Regulations Part 257 (40 CFR 257) (“the Coal Combustion Residuals [CCR] Rule”, or “the Rule”) and the specific requirement of 40 CFR § 257.82(c)(4) that “(t)he owner or operator of the CCR unit must prepare periodic inflow design flood control system plans required by paragraph (c)(1) of this section every five years.”

2. Methodology

The methodology used to prepare this 2021 Periodic Inflow Design Flood Control System Plan for the Combined Waste Treatment Pond (CWTP) at the Four Corners Power Plant is for the certifying Qualified Professional Engineer (QPE) to:

- a. Identify and review the hydrologic design basis references used for the 2016 Plan and verify applicability for use in 2021.
- b. Perform a documented review of each major component of the contributing technical information from:
 - i. AECOM, 2016, Four Corners Power Plant, Combined Waste Treatment Pond, Inflow Design Flood Control System Plan, FC_InflowFlood_012_20161017, August 31, 2016, (hereafter referred to as the “2016 Plan” and incorporated and referenced directly as Attachment A to this document).
- c. Consider and document whether the 2016 Plan and its conclusions:
 - i. Meet the current reporting requirements of the Rule;
 - ii. Reflect the current condition of the structure, as known to the QPE and documented in the annual inspections;
 - iii. Are compromised by any identified issues of concern; and
 - iv. Are consistent with the standard of care of professionals performing similar evaluations in this region of the country; and
- d. Identify any additional analyses, investigations, inspections, and/or repairs that should be completed in order to complete this 2021 Recertification.

This plan documents the results of these considerations, incorporates the 2016 Plan as an Appendix, identifies any additional technical investigation or evaluations (if needed), and presents an updated certification by the QPE.

3. Applicability of 2016 Plan Hydrologic Design Basis

In 2016, the CWTP was an active pond, receiving a gravity inflow of bottom ash sluice water estimated at an average of 5 million gallons per day (MGD). With a pond surface area of approximately 13.4 acres, the daily inflow was equivalent to over 12 inches of direct precipitation on the pond, every day. Therefore, the hydrologic methodology presented in the 2016 Plan followed a flood routing protocol with the following steps:

- a. Estimate the 100-Year, 24-Hour precipitation depth as 2.36 inches from NOAA 14;
- b. Derive the modified SCS rainfall distribution, per New Mexico Department of Transportation (NMDOT) Hydrology Manual;
- c. Estimate the 100-Year, 24-Hour event contribution to the CWTP as 19.6 acre-feet; and
- d. Use HEC-HMS 4.1 to route the storm precipitation through the operating pond, to obtain a maximum water surface elevation in the pond, and to show that the two-foot required embankment freeboard was maintained.

In 2021, the Plant has ceased daily discharge to the CWTP, lowered the normal operating level by 2.5 feet, and now requires that the IDF be stored within the allowed freeboard and not discharged through the outlet works. In reviewing the applicability of the 2016 Plan hydrologic design basis to requirements in 2021, AECOM has verified the following:

- a. The tributary area to the pond has decreased significantly because:
 - i. In 2016, a significant portion of the attributed tributary area were gathered in sumps, pumped to the elevated Pirate Ship tank, and then drained by gravity to the CWTP;
 - ii. In 2021, all flows pumped to the Pirate Ship tank now flow by gravity to the Bottom Ash Sluice Water Return (BASWR) tank.
 - iii. Therefore, the tributary area used for the 2016 Plan can be considered significantly conservative relative to the actual tributary area in 2021.
- b. NOAA Atlas 14 Volume 1 remains the applicable precipitation frequency guide for New Mexico;
- c. The NMDOT Hydrology Manual was updated in 2018 but the results for rainfall distribution do not change;
- d. Site surfacing, grading, and other conditions have not changed, so the surface runoff coefficients used in the 2016 Plan remain valid; and
- e. The normal operating level has been lowered from Elevation 5332.01 feet (NAVD88), as reported in the 2016 Plan, to approximate Elevation 5329.5 feet (NAVD88), just below the inlet apron of the outlet works, in order not to allow discharge from the CWTP to the Plant's cooling water canal.

In summary, the IDF precipitation estimate of 2.36 inches remains valid, the tributary area is now smaller than in 2016 by an undetermined but significant amount, the runoff coefficients remain valid, and the normal pond level has been lowered to Elevation 5329.5 (NAVD88). The 2016 Plan estimated the 100-Year, 24-Hour event inflow and direct precipitation on the CWTP as 19.6 acre-feet, which is equivalent to a depth of 1.46 feet over the combined 13.4-acre area

of the CWTP decant cells and free water pond. With a normal operating level of 5329.5 feet (NAVD88), the maximum flood pool resulting from the IDF would be, conservatively, 5231.0 feet (NAVD88), which is 5.4 feet lower than the embankment crest elevation of 5336.4 feet (NAVD88) reported in the 2016 Plan.

AECOM concludes that the runoff volume likely to flow to the CWTP during the IDF is significantly lower in 2021 than in 2016, that the hydrologic basis for the derivations used in the 2016 Plan are conservative yet still valid in 2021, and that the estimated 19.6 acre-feet of runoff from the IDF, with no discharge from the stop-logged outlet works, would pool in the CWTP to an elevation 5.4 feet below the crest of the embankment. Therefore, this section of the 2016 Plan, as amended by this analysis, adequately represents current conditions and satisfies the requirements of the Rule.

4. 2016 Plan – Review by Section

Other than as described in the remainder of this section, the details presented in this section of the 2016 Plan adequately represent current conditions and satisfy the requirements of the Rule.

4.1 “§257.82 Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”

The details presented in this section of the 2016 Plan accurately describe the requirements of the Rule.

4.2 “Overview”

The details presented in this section of the 2016 Plan adequately represent current conditions and satisfy the requirements of the Rule, with the following updates to reflect 2021 conditions.

In November 2020, APS ceased discharge of sluiced bottom ash to the CWTP. Flows instead are routed to a new Bottom Ash Sluice Water Return (BASWR) tank. APS intends to close the CWTP by dredge removal of bottom ash sediments within the time frames allowed by the Rule for a surface impoundment of this size.

In 2018, APS made minor improvements to the CWTP embankment that included adding fill to restore crest height in left abutment area. The minimum crest height is now greater than reported in the 2016 Plan.

In 2021, the normal operating level has been lowered from Elevation 5332.01 feet (NAVD88), as reported in the 2016 Plan, to approximate Elevation 5329.5 feet (NAVD88), just below the apron of the outlet works, in order not to allow discharge from the CWTP to the Plant’s cooling water canal. The pond is refilled by temporary pump with water from the cooling water canal to maintain hydrostatic balance between the water levels in the Pond and in the adjacent cooling water canal.

4.3 “§257.82 (a)(1)(2)(3) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”

A separate 2021 Periodic Hazard Potential Study confirms the assignment of the lowest classification, Low Hazard Potential, to the CWTP. Therefore, this aspect of the 2016 Plan adequately represents current conditions and satisfies the requirements of the Rule.

Operational aspects described in the 2016 Plan have changed significantly due to the cessation of discharge of bottom ash sluice water to the CWTP in 2020. The majority of these changes are described in Section “3. Applicability of 2016 Plan Hydrologic Design Basis” of this 2021 Plan. In addition, the following changes relative to information presented in this section of the 2016 Plan are documented:

- a. The estimate of 15 MGD discharge reported in the 2016 Plan is now believed to have been affected by a measurement error and the more reasonable estimate would have been 5 MGD. As stated, this discharge is now directed to the BASWR tank, which discharges to the cooling water canal.
- b. The CWTP is now blocked from discharging to the cooling water canal and Morgan Lake.

Therefore, this section of the 2016 Plan, as amended by this analysis, adequately represents current conditions and satisfies the requirements of the Rule.

4.4 “§257.82 (b) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”

The details presented in this section of the 2016 Plan no longer represent current conditions. There is no longer a discharge from the CWTP to Morgan Lake, therefore this requirement of the Rule is satisfied.

4.5 “§257.82 (c) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”

The owner or operator continues to acknowledge and will comply with these requirements.

Per the requirement of §257.82 (c)(4), this document constitutes the “every five years” Periodic Inflow Design Flood Control System Plan.

A certification of this Periodic Inflow Design Flood Control System Plan by a QPE is included in this document per the requirement of §257.82(c)(5).

4.6 “§257.82 (d) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments”

The owner or operator continues to acknowledge and will comply with these requirements.

5. Recommended Additional Technical Investigations or Evaluations

None identified and none recommended.

6. Conclusion

The 2016 Plan and its conclusions, as amended by the analyses presented in this 5-Year periodic revision, meet the current reporting requirements of the Rule, reflect the current condition of the structure as known to the QPE and documented in the annual inspections, are not compromised by any identified issues of concern, and are consistent with the standard of care of professionals performing similar evaluations in this region of the country.

7. Limitations

This document is for the sole use of APS on this project only and is not to be used for other projects. In the event that conclusions based upon the data presented in this document are made by others, such conclusions are the responsibility of others.

The Periodic Inflow Design Flood Control System Plan presented in this report is based on the 2016 Plan and relies and incorporates any Limitations expressed in that document.

The Certification of Professional Opinion in this report is limited to the information available to AECOM at the time this Assessment was performed in accordance with current practice and the standard of care. Standard of care is defined as the ordinary diligence exercised by fellow practitioners in this area performing the same services under similar circumstances during the same period. Professional judgments presented herein are primarily based on information from previous reports that have been assumed to be accurate, knowledge of the site, and partly on our general experience with dam safety evaluations performed on other dams.

No warranty or guarantee, either written or implied, is applicable to this work. The use of the word “certification” and/or “certify” in this document shall be interpreted and construed as a Statement of Professional Opinion and is not and shall not be interpreted or construed as a guarantee, warranty, or legal opinion.

8. Certification Statement


Certification Statement for:

- Certification Statement 40 CFR § 257.82(c)(5) – Periodic Inflow Design Flood Control System Plan for an Existing CCR Surface Impoundment.
- CCR Unit: Arizona Public Service; Four Corners Power Plant; Combined Waste Treatment Pond

I, Alexander W. Gourlay, being a Registered Professional Engineer in good standing in the State of New Mexico, do hereby certify, to the best of my knowledge, information, and belief, that the information contained in this certification has been prepared in accordance with the accepted practice of engineering. I certify, for the above-referenced CCR Unit, that the information contained in this Periodic Inflow Design Flood Control System Plan dated October 2021, including the technical content in Attachment A, meets the requirements of 40 CFR § 257.81.

Alexander W. Gourlay, P.E.
Printed Name

October 11, 2021
Date



Attachment A:

AECOM, 2016, Four Corners Power Plant, Combined Waste Treatment Pond, Inflow Design Flood Control System Plan, FC_InflowFlood_012_20161017, August 31, 2016.

ATTACHMENT A

AECOM, 2016, *Four Corners Power Plant, Combined Waste Treatment Pond, Inflow Design Flood Control System Plan, FC_InflowFlood_012_20161017, August 31, 2016.*

**FOUR CORNERS POWER PLANT
COMBINED WASTE TREATMENT POND
INFLOW DESIGN FLOOD CONTROL SYSTEM PLAN
FC_InflowFlood_012_20161017**

This *Inflow Design Flood Control System Plan* (Plan) document has been prepared specifically for the Combined Water Treatment Pond (CWTP) at the Four Corners Power Plant. This Plan has been prepared in accordance with our understanding of the requirements prescribed in §257.82 of the Federal Register, Volume 80, Number 74, dated April 17, 2015 (U. S. Government, 2015) for hydrologic and hydraulic capacity requirements for CCR surface impoundments associated with existing Coal Combustion Residual (CCR) surface impoundments. Section §257.82 is reproduced below for reference purposes. This document serves as the *initial plan* described in §257.82.

The CWTP is an existing CCR surface impoundment facility. Calculations have been prepared in support of the facility operation and have been included herein to address the requirements listed.

§257.82 Hydrologic and Hydraulic capacity requirements for CCR surface impoundments

(a) The owner or operator of an existing or new CCR surface impoundment or any lateral expansion of a CCR surface impoundment must design, construct, operate, and maintain an inflow design flood control system as specified in paragraphs (a)(1) and (2) of this section.

(1) The inflow design flood control system must adequately manage flow into the CCR unit during and following the peak discharge of the inflow design flood specified in paragraph (a)(3) of this section.

(2) The inflow design flood control system must adequately manage flow from the CCR unit to collect and control the peak discharge resulting from the inflow design flood specified in paragraph (a)(3) of this section.

(3) The inflow design flood is:

(i) For a high hazard potential CCR surface impoundment, as determined under §257.73(a)(2) or §257.74(a)(2), the probable maximum flood;

(ii) For a significant hazard potential CCR surface impoundment, as determined under §257.73(a)(2) or §257.74(a)(2), the 1,000-year flood;

(iii) For a low hazard potential CCR surface impoundment, as determined under §257.73(a)(2) or §257.74(a)(2), the 100-year flood; or

(iv) For an incised CCR surface impoundment, the 25-year flood.

(b) Discharge from the CCR unit must be handled in accordance with the surface water requirements under §257.3-3.

(c) *Inflow design flood control system plan* –

(1) *Content of the Plan.* The owner or operator must prepare initial and periodic inflow design flood control system plans for the CCR unit according to the timeframes specified in paragraphs (c)(3) and (4) of this section. These plans must document how the inflow design flood control system has been designed and constructed to meet the requirements of this section. Each plan must be supported by appropriate engineering calculations. The owner or operator of the CCR unit has completed the inflow design flood control system plan when the plan has been placed in the facility's operating record as required by §257.105(g)(4).

(2) *Amendment of the Plan.* The owner or operator of the CCR unit may amend the written inflow design flood control system plan at any time provided the revised plan is placed in the facility's operating record as required by §257.105(g)(4). The owner or operator must amend the written inflow design flood control system plan whenever there is a change in conditions that would substantially affect the written plan in effect.

(3) *Timeframes for preparing the initial plan -*

(i) *Existing CCR surface impoundments.* The owner or operator must prepare the initial inflow design flood control system plan no later than October 17, 2016.

(ii) *New CCR surface impoundments and any lateral expansion of a CCR surface impoundment.* The owner or operator must prepare the initial inflow design flood control system plan no later than the date of initial receipt of CCR in the CCR unit.

(4) *Frequency for revising the plan.* The owner or operator must prepare periodic inflow design flood control system plans required by paragraph (c)(1) of this section every five years. The date of completing the initial plan is the basis for establishing the deadline to complete the first periodic plan. The owner or operator may complete any required plan prior to the required deadline provided the owner or operator places the completed plan into the facility's operating record within a reasonable amount of time. In all cases, the deadline for completing a subsequent plan is based on the date of completing the previous plan. For purposes of this paragraph (c)(4), the owner or operator has completed an inflow design flood control system plan when the plan has been placed in the facility's operating record as required by §257.105(g)(4).

(5) The owner or operator must obtain a certification from a qualified engineer stating that the initial and periodic inflow design flood control system plans meet the requirements of this section.

(d) The owner or operator of the CCR unit must comply with the record keeping requirements specified in §257.105(g), the notification requirements specified in §257.106(g), and the internet requirements specified in §257.107(g).

SITE INFORMATION	
Site Name / Address	Four Corners Power Plant / 691 CR-6100, Fruitland, NM 85416
Owner Name / Address	Arizona Public Service / 400 North 5 th Street, Phoenix, AZ 85004
CCR Unit	Combined Waste Treatment Pond (CWTP)
<p>OVERVIEW</p> <p>The CWTP located at the Four Corners Power Plant (FCPP) (Exhibit 1) receives storm water inflow from sumps located in Units 4 and 5, the coal blending area, and from the area of decommissioned Units 1,2, and 3. This is in addition to the direct precipitation associated with the impoundment. The impoundment embankment has an average height of 23 feet and the lowest elevation on the crest of the embankment is 5336.4 feet (NAVD88). The normal operating water level in CWTP is assumed to be 5332.01 feet based on survey data.</p> <p>This inflow / flood control plan describes the contributing runoff volumes and storage capacities estimated for the CWTP.</p>	

§257.82 (a)(1)(2)(3) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments

<p>(a) The owner or operator of an existing or new CCR surface impoundment or any lateral expansion of a CCR surface impoundment must design, construct, operate, and maintain an inflow design flood control system as specified in paragraphs (a)(1) and (2) of this section.</p> <p>(1) The inflow design flood control system must adequately manage flow into the CCR unit during and following the peak discharge of the inflow design flood specified in paragraph (a)(3) of this section.</p>	<p>The 100-Year 24-Hour storm water runoff produced from the contributing watershed is 19.58 acre-feet, as shown in the calculations included in Appendix 1. This volume is based on a 2.36 inch precipitation depth, and a runoff curve number of 95 for the facilities and 100 for the pond impoundment.</p> <p>The CWTP receives an average 15 million gallons per day of water from the plant during normal operations. The CWTP receives runoff from direct precipitation and runoff from the units and coal processing area which is collected in drains and trenches and is pumped to the CWTP with the normal operating water. The pumped inflow is conveyed through a 48-inch pipe to the CWTP. The runoff is detained in the CWTP and discharged into Morgan Lake through two 36-inch pipes. The normal operating water surface elevation is 5332.01 feet with a crest elevation of 5336.4 feet based on survey data. The maximum water elevation is 5334.4 feet. There is 2.0 feet of freeboard from the maximum water elevation to the lowest crest elevation.</p>
<p>(a) The owner or operator of an existing or new CCR surface impoundment or any lateral expansion of a CCR surface impoundment must design, construct, operate, and maintain an inflow design flood control system as specified in paragraphs (a)(1) and (2) of this section.</p> <p>(2) The inflow design flood control system must adequately manage flow from the CCR unit to collect and control the peak discharge resulting from the inflow design flood specified in paragraph (a)(3) of this section.</p>	<p>The 100-Year 24-Hour storm water runoff is discharged from the CWTP to Morgan Lake through two 36" RCP pipes. The discharge pipes have sufficient capacity to handle the stormwater discharge and the normal operating flow with a maximum water elevation of 5334.4 feet.</p> <p>Refer to response to (a)(1) for additional details regarding the Inflow Design Flood Control System Plan for the URS.</p>

<p>(a)(3) The inflow design flood is:</p> <p>(i) For a high hazard potential CCR surface impoundment, as determined under §257.73(a)(2) or §257.74(a)(2), the probable maximum flood;</p> <p>(ii) For a significant hazard potential CCR surface impoundment, as determined under §257.73(a)(2) or §257.74(a)(2) , the 1,000-year flood;</p> <p>(iii) For a low hazard potential CCR surface impoundment, as determined under §257.73(a)(2) or §257.74(a)(2), the 100-year flood; or</p> <p>(iv) For an incised CCR surface impoundment, the 25-year flood.</p>	<p>The hazard classification for the CWTP is low, based on the Final Summary Report Structural Integrity Assessment, Combined Waste Treatment Pond, Four Corners Power Plant, prepared by AECOM in August 2016 (AECOM 2016).</p>
<p>§257.82 (b) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments</p>	
<p>(b) Discharge from the CCR unit must be handled in accordance with the surface water requirements under §257.3-3.</p>	<p>The CWTP discharges into Morgan Lake as permitted by the current NPDES permit. The discharge is tested weekly to verify that the discharge does not exceed the permitted level for total suspended solids, oil, and grease. No dredged or fill material is being discharged.</p>
<p>§257.82 (c) Hydrologic and Hydraulic capacity requirements for CCR surface impoundments</p>	
<p>(c)(1) <i>Content of the plan.</i> The owner or operator must prepare initial and periodic inflow design flood control system plans for the CCR unit according to the timeframes specified in paragraphs (c)(3) and (4) of this section. These plans must document how the inflow design flood control system has been designed and constructed to meet the requirements of this section. Each plan must be supported by appropriate engineering calculations. The owner or operator of the CCR unit has completed the inflow design flood control system plan when the plan has been placed in the facility’s operating record as required by §257.105(g)(4).</p>	<p>This <i>Inflow Design Flood Control Plan</i> serves as the initial plan prescribed herein.</p>

<p>(c)(2) <i>Amendment of the Plan.</i> The owner or operator of the CCR unit may amend the written inflow design flood control system plan at any time provided the revised plan is placed in the facility's operating record as required by §257.105(g)(4). The owner or operator must amend the written inflow design flood control system plan whenever there is a change in conditions that would substantially affect the written plan in effect.</p>	<p>The owner or operator acknowledges and will comply with this requirement.</p>
<p>(c)(3) <i>Timeframes for preparing the initial plan –</i></p> <p>(i) Existing CCR impoundments. The owner or operator must prepare the initial inflow design flood control system plan no later than October 17, 2016.</p> <p>(ii) New CCR surface impoundments and any lateral expansion of a CCR surface impoundment. The owner or operator must prepare the initial inflow design flood control system plan no later than the date of initial receipt of CCR in the CCR Unit</p>	<p>The CWTP is an existing CCR impoundment at Four Corners Power Plant. The inflow design flood control system plan is included herein.</p> <p>The owner or operator acknowledges and will comply with this requirement.</p>

<p>(c)(4) Frequency for revising the plan. The owner or operator must prepare periodic inflow design flood control system plans required by paragraph (c)(1) of this section every five years. The date of completing the initial plan is the basis for establishing the deadline to complete the first periodic plan. The owner or operator may complete any required plan prior to the required deadline provided the owner or operator places the completed plan into the facility's operating record within a reasonable amount of time. In all cases, the deadline for completing a subsequent plan is based on the date of completing the previous plan. For purposes of this paragraph (c)(4), the owner or operator has completed an inflow design flood control system plan when the plan has been placed in the facility's operating record as required by §257.105(g)(4).</p>	<p>The owner or operator acknowledges and will comply with this requirement.</p>
<p>(c)(5) The owner or operator must obtain a certification from a qualified professional engineer stating that the initial and periodic inflow design flood control system plans meet the requirements of this section.</p>	<p>Certification by a professional engineer is included as an attachment to this document.</p>
<p>§257.82 (d) RECORDKEEPING, NOTIFICATION, AND INTERNET REQUIREMENTS</p>	
<p>(d) The owner or operator of the CCR unit must comply with the recordkeeping requirements specified in §257.105(g), the notification requirements specified in §257.106(g), and the internet requirements specified in §257.107(g).</p>	<p>The owner or operator acknowledges and will comply with this requirement.</p>

References

AECOM, August 2016, **Final Summary Report Structural Integrity Assessment, Combined Waste Treatment Pond, Four Corners Power Plant.**

U.S. Government, April 2015, **Federal Register, Volume 80, Number 74, Rules and Regulations.**

Certification Statement 40 CFR § 257.82(c)(5) –Initial Inflow Design Flood Control System Plan for an Existing CCR Surface Impoundment

CCR Unit: Arizona Public Service; Four Corners Power Plant; Combined Waste Treatment Pond


I, Alexander W. Gourlay, being a Registered Professional Engineer in good standing in the State of New Mexico, do hereby certify, to the best of my knowledge, information, and belief, that the information contained in this certification has been prepared in accordance with the accepted practice of engineering. I certify, for the above-referenced CCR Unit, that the information contained in the initial inflow design flood control system plan dated August, 31, 2016 meets the requirements of 40 CFR § 257.82.

Alexander W. Gourlay, P.E.

Printed Name

August 31, 2016

Date



APPENDIX 1 - CALCULATIONS

PROBLEM STATEMENT:

The purpose of this calculation package is to document the hydrologic analysis prepared by AECOM for the watershed draining toward the CWTP.

REQUIRED DELIVERABLES:

- Maximum stage in the CTWP for a 100-year 24-hour storm.

DATA /ASSUMPTIONS:

- The inflow to the pond for the various watersheds is conveyed through a 48" pipe. A constant discharge of 59.68 cfs (26,787 gpm) was assumed as inflow.
- The stage-volume for the CWTP was entered.
- The precipitation value of 2.36 inches for the 100-yr 24-hr storm was obtained from NOAA 14. The modified SCS rainfall distribution was used as per New Mexico Department of Transportation (NMDOT) Hydrology Manual.
- The normal operating water surface elevation in the CWTP pond is assumed to be 5332.01 feet.
- The discharge from the pond is conveyed by two – 36 " RCP pipe that drains in to the Morgan Lake. The stage discharge rating table for the outlet pipes that was developed using CulvertMaster was entered as outflow input.
- HEC-HMS 4.1 was utilized to obtain a maximum water surface elevation.
- Calculation results are provided based on NAVD88 vertical datum. As-builts are based on NGVD29. A conversion factor of 3.012 feet was used to convert NGVD29 to NAVD88.

RESULTS:

The HEC-HMS model calculated a maximum water surface elevation of 5334.4 feet with the above mentioned inputs. The maximum stage is 2 feet below the crest elevation of 5336.4 feet. Figures 1 and 2 illustrate the model and global summary table of the HEC-HMS simulation run. Figure 3 delineates the drainage areas contributing to the CWTP. The stage storage calculation and volumes are shown in Table 1. The total runoff volume calculation for the CWTP and contributing facility areas are shown in Table 2.

Figure 1 – HEC HMS Schematic




Figure 2 – HEC-HMS Output

Summary Results for Reservoir "CWTP"

Project: CWTP_Basin_100yr Simulation Run: Run 1
Reservoir: CWTP

Start of R...	01Jan2050, 00:00	Basin Model:	CTWP
End of R...	02Jan2050, 00:00	Meteorologic Model:	Modified SCS 100-yr; 24-h
Compute Ti...	12Jul2016, 13:54:04	Control Specifications:	Control 1

Volume Units: IN AC-FT

Computed Results

Peak Inflow:	98.9 (CFS)	Date/Time of Peak Inflow:	01Jan2050, 00:20
Peak Discharge:	59.8 (CFS)	Date/Time of Peak Discharge:	02Jan2050, 00:00
Inflow Volume:	n/a	Peak Storage:	18.6 (AC-FT)
Discharge Volume:	n/a	Peak Elevation:	5334.4 (FT)


Table 1 – Stage Storage Volume

STAGE	DEPTH	AREA	VOL _{INC}	VOL _{INC}	VOL _{CUM}	VOL _{CUM}
	[ft]	[ft ²]	[ft ³]	[ac-ft]	[ft ³]	ac-ft
5,332.01	0.00	315,071.43	0.00	0.00	0.00	0.00
5,333.00	0.99	320,323.51	314,520	7.22	314,520	7.22
5,334.00	1.99	330,034.00	325,179	7.47	639,699	14.69
5,335.00	2.99	557,820.66	443,927	10.19	1,083,627	24.88
5,336.00	3.99	606,436.41	582,129	13.36	1,665,755	38.24

Table 2 – Retention Volume Calculation – 100-YR Storm



Sub-basin	Area (sq ft)	Area (acre)	Curve number	Precipitation	Direct runoff	Runoff Volume
			CN	P (inch)	Qd (inch)	Qv (ac-ft)
Units 1, 2 & 3	1737090	39.88	95	2.36	1.83	6.07
Units 4&5	1211456	27.81	95	2.36	1.83	4.24
Coal Blending Area	1852488	42.53	95	2.36	1.83	6.48
CWTP	685262	15.73	98	2.36	2.13	2.79
				TOTAL (ac-ft)		19.58

FIGURE 3



SUPPORTING DOCUMENTS

HEC-HMS DATA



100-YEAR, 24 HOUR RAINFALL DISTRIBUTION

ARIZONA PUBLIC SERVICES, FARMINGTON, NM
 FOUR CORNERS POWER PLANT CCR - CWTP
 MODIFIED NOAA-SCS RAINFALL DISTRIBUTION

NOAA 14 Depth Duration Frequency Data [100-YEAR]⁽¹⁾:

DURATION	[hours]	[inches] ⁽¹⁾
0	0	0
5-min	0.0833	0.523
10-min	0.1667	0.796
15-min	0.2500	0.986
30-min	0.5000	1.330
	0.7500	1.485
1-hr	1.0000	1.640
	1.2500	1.690
	1.5000	1.740
	1.7500	1.790
2-hr	2.0000	1.840
	2.5000	1.850
3-hr	3.0000	1.860
	3.5000	1.890
	4.0000	1.920
	5.0000	1.980
6-hr	6.0000	2.040
	7.0000	2.067
	8.0000	2.093
	9.0000	2.120
	10.0000	2.147
	11.0000	2.173
12-hr	12.0000	2.200
	14.0000	2.227
	16.0000	2.253
	18.0000	2.280
	20.0000	2.307
	22.0000	2.333
24-hr	24.0000	2.360

Modified NOAA-SCS Rainfall Distribution⁽²⁾:

n	TIME [hours]	CUMULATIVE DEPTH [inches]	INCREMENTAL DEPTH [inches]	HYETOGRAPH TIME PERIOD (hrs)	n [REARRANGED]	INCREMENTAL DEPTH [inches]	CUMULATIVE DEPTH [inches]	CUMULATIVE DEPTH [%]
0	0	0.000		0.00 TO 1.00	19	0.027	0.027	0.011
1	0.25	0.986	0.986	1.00 TO 2.00	17	0.027	0.053	0.023
2	0.5	1.330	0.344	2.00 TO 3.00	15	0.027	0.080	0.034
3	0.75	1.485	0.155	3.00 TO 4.00	13	0.060	0.140	0.059
4	1	1.640	0.155	4.00 TO 4.50	11	0.030	0.170	0.072
5	1.25	1.690	0.050	4.50 TO 5.00	9	0.010	0.180	0.076
6	1.5	1.740	0.050	5.00 TO 5.25	7	0.050	0.230	0.097
7	1.75	1.790	0.050	5.25 TO 5.50	5	0.050	0.280	0.119
8	2	1.840	0.050	5.50 TO 5.75	3	0.155	0.435	0.184
9	2.5	1.850	0.010	5.75 TO 6.00	1	0.986	1.421	0.602
10	3	1.860	0.010	6.00 TO 6.25	2	0.344	1.765	0.748
11	3.5	1.890	0.030	6.25 TO 6.50	4	0.155	1.920	0.814
12	4	1.920	0.030	6.50 TO 6.75	6	0.050	1.970	0.835
13	5	1.980	0.060	6.75 TO 7.00	8	0.050	2.020	0.856
14	6	2.040	0.060	7.00 TO 7.50	10	0.010	2.030	0.860
15	7	2.067	0.027	7.50 TO 8.00	12	0.030	2.060	0.873
16	8	2.093	0.027	8.00 TO 9.00	14	0.060	2.120	0.898
17	9	2.120	0.027	9.00 TO 10.00	16	0.027	2.147	0.910
18	10	2.147	0.027	10.00 TO 11.00	18	0.027	2.173	0.921
19	11	2.173	0.027	11.00 TO 12.00	20	0.027	2.200	0.932
20	12	2.200	0.027	12.00 TO 14.00	21	0.027	2.227	0.944
21	14	2.227	0.027	14.00 TO 16.00	22	0.027	2.253	0.955
22	16	2.253	0.027	16.00 TO 18.00	23	0.027	2.280	0.966
23	18	2.280	0.027	18.00 TO 20.00	24	0.027	2.307	0.977
24	20	2.307	0.027	20.00 TO 22.00	25	0.027	2.333	0.989
25	22	2.333	0.027	22.00 TO 24.00	26	0.027	2.360	1.000
26	24	2.360	0.027					

Notes:

1. Precipitation depth, duration, frequency data based on NOAA Atlas 14 Online Precipitation Data Frequency Server.
2. Modified NOAA-SCS rainfall distribution developed based on procedures prescribed by New Mexico State Highway and Transportation Department's *Drainage Manual, Volume I*, 1995.
3. Rainfall data based on Blanco Arroyo watershed centroid located at Latitude 36.8170° N Longitude 107.9810° W

100-YEAR HMS

time [hrs]	[inches]	time [hrs]	[inches]
0	0	0.00	0.000
0.25	0.986	0.25	0.986
0.5	1.33	0.50	1.330
0.75	1.485	0.75	1.485
1	1.64	1.00	1.640
1.25	1.69	1.25	1.690
1.5	1.74	1.50	1.740
1.75	1.79	1.75	1.790
2	1.84	2.00	1.840
2.5	1.85	2.25	1.845
3	1.86	2.50	1.850
3.5	1.89	2.75	1.855
4	1.92	3.00	1.860
5	1.98	3.25	1.875
6	2.04	3.50	1.890
7	2.066667	3.75	1.905
8	2.093333	4.00	1.920
9	2.12	4.25	1.935
10	2.146667	4.50	1.950
11	2.173333	4.75	1.965
12	2.2	5.00	1.980
14	2.226667	5.25	1.995
16	2.253333	5.50	2.010
18	2.28	5.75	2.025
20	2.306667	6.00	2.040
22	2.333333	6.25	2.047
24	2.36	6.50	2.053
		6.75	2.060
		7.00	2.067
		7.25	2.073
		7.50	2.080
		7.75	2.087
		8.00	2.093
		8.25	2.100
		8.50	2.107
		8.75	2.113
		9.00	2.120
		9.25	2.127
		9.50	2.133
		9.75	2.140
		10.00	2.147
		10.25	2.153
		10.50	2.160
		10.75	2.167
		11.00	2.173
		11.25	2.180
		11.50	2.187
		11.75	2.193
		12.00	2.200
		12.25	2.203
		12.50	2.207
		12.75	2.210
		13.00	2.213
		13.25	2.217
		13.50	2.220
		13.75	2.223
		14.00	2.227
		14.25	2.230
		14.50	2.233
		14.75	2.237
		15.00	2.240
		15.25	2.243
		15.50	2.247
		15.75	2.250
		16.00	2.253
		16.25	2.257
		16.50	2.260
		16.75	2.263
		17.00	2.267
		17.25	2.270
		17.50	2.273
		17.75	2.277
		18.00	2.280
		18.25	2.283
		18.50	2.287
		18.75	2.290
		19.00	2.293
		19.25	2.297
		19.50	2.300
		19.75	2.303
		20.00	2.307
		20.25	2.310
		20.50	2.313
		20.75	2.317
		21.00	2.320
		21.25	2.323
		21.50	2.327
		21.75	2.330
		22.00	2.333
		22.25	2.337
		22.50	2.340
		22.75	2.343
		23.00	2.347
		23.25	2.350
		23.50	2.353
		23.75	2.357
		24.00	2.360

NOAA 14 PRECIPITATION INFORMATION



NOAA Atlas 14, Volume 1, Version 5
Location name: Waterflow, New Mexico, US*
Latitude: 36.6899°, Longitude: -108.4778°
Elevation: 5334 ft*
 * source: Google Maps



POINT PRECIPITATION FREQUENCY ESTIMATES

Sanja Perica, Sarah Dietz, Sarah Heim, Lillian Hiner, Kazungu Maitaria, Deborah Martin, Sandra Pavlovic, Ishani Roy, Carl Trypaluk, Dale Unruh, Fenglin Yan, Michael Yekta, Tan Zhao, Geoffrey Bonnin, Daniel Brewer, Li-Chuan Chen, Tye Parzybok, John Yarchoan

NOAA, National Weather Service, Silver Spring, Maryland

[PF tabular](#) | [PF graphical](#) | [Maps & aerials](#)



PF tabular

PDS-based point precipitation frequency estimates with 90% confidence intervals (in inches)¹										
Duration	Average recurrence interval (years)									
	1	2	5	10	25	50	100	200	500	1000
5-min	0.147 (0.126-0.172)	0.190 (0.162-0.221)	0.255 (0.219-0.296)	0.309 (0.265-0.360)	0.387 (0.328-0.451)	0.452 (0.380-0.525)	0.521 (0.433-0.605)	0.596 (0.489-0.694)	0.703 (0.565-0.821)	0.792 (0.627-0.929)
10-min	0.224 (0.192-0.261)	0.288 (0.247-0.336)	0.388 (0.333-0.451)	0.471 (0.403-0.548)	0.590 (0.500-0.686)	0.688 (0.578-0.799)	0.792 (0.659-0.922)	0.907 (0.745-1.06)	1.07 (0.860-1.25)	1.21 (0.954-1.41)
15-min	0.277 (0.238-0.324)	0.358 (0.307-0.416)	0.481 (0.413-0.559)	0.584 (0.500-0.680)	0.731 (0.620-0.851)	0.853 (0.717-0.990)	0.982 (0.817-1.14)	1.12 (0.923-1.31)	1.33 (1.07-1.55)	1.49 (1.18-1.75)
30-min	0.373 (0.321-0.436)	0.482 (0.413-0.561)	0.647 (0.557-0.753)	0.786 (0.673-0.915)	0.984 (0.835-1.15)	1.15 (0.966-1.33)	1.32 (1.10-1.54)	1.51 (1.24-1.76)	1.79 (1.44-2.09)	2.01 (1.59-2.36)
60-min	0.462 (0.397-0.540)	0.596 (0.511-0.694)	0.801 (0.689-0.932)	0.973 (0.833-1.13)	1.22 (1.03-1.42)	1.42 (1.20-1.65)	1.64 (1.36-1.90)	1.87 (1.54-2.18)	2.21 (1.78-2.58)	2.49 (1.97-2.92)
2-hr	0.503 (0.439-0.583)	0.638 (0.559-0.741)	0.851 (0.746-0.983)	1.03 (0.898-1.19)	1.29 (1.11-1.49)	1.51 (1.29-1.74)	1.75 (1.47-2.02)	2.01 (1.67-2.32)	2.40 (1.94-2.78)	2.72 (2.16-3.17)
3-hr	0.555 (0.493-0.632)	0.699 (0.618-0.800)	0.910 (0.807-1.04)	1.09 (0.957-1.23)	1.35 (1.18-1.52)	1.56 (1.35-1.77)	1.80 (1.53-2.04)	2.05 (1.73-2.34)	2.44 (2.01-2.79)	2.75 (2.23-3.18)
6-hr	0.651 (0.588-0.730)	0.808 (0.728-0.905)	1.02 (0.918-1.15)	1.20 (1.08-1.34)	1.47 (1.30-1.64)	1.69 (1.48-1.88)	1.92 (1.66-2.15)	2.17 (1.86-2.44)	2.55 (2.13-2.88)	2.86 (2.34-3.24)
12-hr	0.759 (0.688-0.842)	0.944 (0.855-1.05)	1.17 (1.06-1.30)	1.35 (1.22-1.50)	1.61 (1.44-1.77)	1.81 (1.61-1.99)	2.01 (1.78-2.22)	2.22 (1.95-2.47)	2.57 (2.17-2.91)	2.89 (2.37-3.27)
24-hr	0.834 (0.762-0.913)	1.05 (0.953-1.14)	1.32 (1.20-1.44)	1.54 (1.40-1.69)	1.86 (1.68-2.02)	2.10 (1.90-2.29)	2.36 (2.12-2.58)	2.63 (2.34-2.87)	3.00 (2.65-3.29)	3.29 (2.88-3.62)
2-day	0.943 (0.859-1.03)	1.18 (1.08-1.29)	1.47 (1.34-1.60)	1.70 (1.55-1.85)	2.03 (1.84-2.21)	2.27 (2.06-2.47)	2.53 (2.28-2.75)	2.79 (2.50-3.04)	3.15 (2.80-3.43)	3.42 (3.02-3.73)
3-day	1.01 (0.926-1.11)	1.26 (1.16-1.38)	1.57 (1.44-1.71)	1.81 (1.66-1.97)	2.14 (1.95-2.33)	2.40 (2.18-2.60)	2.66 (2.40-2.89)	2.92 (2.63-3.18)	3.28 (2.93-3.57)	3.55 (3.15-3.88)
4-day	1.08 (0.994-1.18)	1.35 (1.24-1.47)	1.67 (1.53-1.82)	1.92 (1.77-2.09)	2.26 (2.07-2.46)	2.52 (2.30-2.74)	2.79 (2.53-3.03)	3.05 (2.76-3.32)	3.41 (3.06-3.72)	3.67 (3.28-4.02)
7-day	1.20 (1.11-1.31)	1.50 (1.37-1.63)	1.84 (1.70-2.00)	2.11 (1.94-2.29)	2.46 (2.27-2.67)	2.73 (2.50-2.95)	2.99 (2.74-3.24)	3.26 (2.96-3.53)	3.60 (3.25-3.90)	3.85 (3.47-4.18)
10-day	1.33 (1.22-1.45)	1.66 (1.53-1.80)	2.04 (1.88-2.21)	2.33 (2.15-2.53)	2.72 (2.50-2.94)	3.00 (2.75-3.24)	3.28 (3.00-3.55)	3.55 (3.24-3.85)	3.90 (3.54-4.23)	4.15 (3.76-4.53)
20-day	1.65 (1.52-1.79)	2.06 (1.89-2.24)	2.54 (2.33-2.75)	2.90 (2.67-3.14)	3.39 (3.11-3.67)	3.75 (3.43-4.06)	4.11 (3.75-4.45)	4.46 (4.05-4.84)	4.92 (4.44-5.35)	5.26 (4.73-5.73)
30-day	1.95 (1.80-2.13)	2.44 (2.24-2.65)	2.99 (2.75-3.25)	3.40 (3.13-3.69)	3.93 (3.61-4.26)	4.31 (3.96-4.68)	4.69 (4.29-5.09)	5.06 (4.61-5.49)	5.51 (5.00-6.00)	5.85 (5.29-6.37)
45-day	2.33 (2.15-2.53)	2.90 (2.68-3.15)	3.56 (3.29-3.85)	4.04 (3.73-4.36)	4.64 (4.28-5.01)	5.07 (4.67-5.47)	5.48 (5.04-5.91)	5.87 (5.38-6.33)	6.33 (5.79-6.84)	6.65 (6.07-7.18)
60-day	2.63 (2.43-2.85)	3.27 (3.02-3.54)	3.98 (3.68-4.30)	4.50 (4.16-4.86)	5.16 (4.76-5.56)	5.62 (5.18-6.05)	6.06 (5.58-6.52)	6.47 (5.94-6.96)	6.96 (6.38-7.50)	7.29 (6.67-7.85)

¹ Precipitation frequency (PF) estimates in this table are based on frequency analysis of partial duration series (PDS). Numbers in parenthesis are PF estimates at lower and upper bounds of the 90% confidence interval. The probability that precipitation frequency estimates (for a given duration and average recurrence interval) will be greater than the upper bound (or less than the lower bound) is 5%. Estimates at upper bounds are not checked against probable maximum precipitation (PMP) estimates and may be higher than currently valid PMP values. Please refer to NOAA Atlas 14 document for more information.

[Back to Top](#)

PF graphical



[Back to Top](#)

NOAA Atlas 14, Volume 1, Version 5

Maps & aeri

Created (GMT): Mon Jun 6 19:12:24 2016

Small scale terrain



Large scale terrain



Large scale map



Large scale aerial



[Back to Top](#)

[US Department of Commerce](#)
[National Oceanic and Atmospheric Administration](#)
[National Weather Service](#)
[National Water Center](#)
1325 East West Highway
Silver Spring, MD 20910

Questions?: HDSC.Questions@noaa.gov


[Disclaimer](#)

PIPE INFLOW INFORMATION

FLOW DIAGRAM LOW VOLUME WASTE - UNITS 1 THRU 5

FOUR CORNERS POWER PLANT — NPDES PROJECTS

FLOW NO.	DESCRIPTION	MAX G.P.M.	AVE. G.P.M.
1	UNITS 1,2,3 HYDROBIN SUMP	8,000	1,300
2	UNITS 1,2,3 WEST AREA SUMP	682	248
3	SUB-TOTAL 1+2	8,682	1,548
4	UNITS 1,2,3 EAST AREA SUMP	3,000	2,571
5	UNITS 4 & 5 SUMP	11,905	4,616
6	COM. EAST AREA SUMP & 4 & 5 SUMP	14,905	7,187
7	SUB-TOTAL 3+6	23,587	8,725
8	UNITS 1,2,3 COAL PILE RUN-OFF	3,200	1,600
9	TOTAL 7+8	26,787	10,325



NO.	DATE	REVISION	APPROVED	DATE	BY
1	8/28/78				
ONE-LINE DIAGRAM LOW VOLUME WASTES					
ARTIZONA PUBLIC SERVICE COMPANY PHOENIX					
SCALE: N.T.S. DATE: 8/28/78					
DRW	APP	ENGR	MANAGER	DRWING NO.	
CK	APP	WA		D-110711	
				SHEET	OF
				1	1

INDEX

CULVERTMASTER REPORT

Rating Table Report

2-36" Pipe Calc

Range Data:

	Minimum	Maximum	Increment
Allowable HW E	5,331.50	5,336.00	0.50 ft

HW Elev. (ft)	Discharge (cfs)
5,331.50	0.00
5,332.00	2.20
5,332.50	8.61
5,333.00	18.64
5,333.50	31.65
5,334.00	46.93
5,334.50	63.74
5,335.00	81.30
5,335.50	98.87
5,336.00	111.84

VERTICAL DATUM CONVERSION SHEET

APS
Four Corners
28 February 2011

INPUT
State Plane, NAD83
3003 - New Mexico West, U.S. Feet
Vertical - NAVD88, U.S. Feet

OUTPUT
State Plane, NAD27
3003 - New Mexico West, U.S. Feet
Vertical - NGVD29 (Vertcon94), U.S. Feet

Accuracies of conversions from NAD 83 to NAD 27 are typically 12 to 18 cm.

3119	1/3
Northing/Y: 2070171.29	Northing/Y: 2070108.945
Easting/X: 2526557.36	Easting/X: 303648.046
Elevation/Z: 5256.59	Elevation/Z: 5253.581
Convergence: -0 24 01.74021	Convergence: -0 24 00.36715
Scale Factor: 0.999960861	Scale Factor: 0.999960779
Combined Factor: 0.999712839	Combined Factor: 0.999709557
Grid Shift (U.S. ft.): X/Easting = -2222909.3, Y/Northing = -62.3	
Datum Shift (m.): Delta Lat. = -0.173, Delta Lon = -57.032	

^Z = 3.009 feet

3124	2/3
Northing/Y: 2068657.97	Northing/Y: 2068595.641
Easting/X: 2528437.23	Easting/X: 305527.916
Elevation/Z: 5325.39	Elevation/Z: 5322.375
Convergence: -0 23 47.73518	Convergence: -0 23 46.36266
Scale Factor: 0.999960020	Scale Factor: 0.999959938
Combined Factor: 0.999708710	Combined Factor: 0.999705427
Grid Shift (U.S. ft.): X/Easting = -2222909.3, Y/Northing = -62.3	
Datum Shift (m.): Delta Lat. = -0.183, Delta Lon = -57.018	

^Z = 3.015 feet


3117	3/3
Northing/Y: 2067386.15	Northing/Y: 2067323.844
Easting/X: 2524575.80	Easting/X: 301666.494
Elevation/Z: 5158.64	Elevation/Z: 5155.628
Convergence: -0 24 15.87006	Convergence: -0 24 14.49696
Scale Factor: 0.999961757	Scale Factor: 0.999961674
Combined Factor: 0.999718419	Combined Factor: 0.999715134
Grid Shift (U.S. ft.): X/Easting = -2222909.3, Y/Northing = -62.3	
Datum Shift (m.): Delta Lat. = -0.178, Delta Lon = -57.049	

^Z = 3.012 feet

USE AVERAGE ^Z = 3.012 feet


Remark: NGVD29 to NAVD88 Vertical Datum Shift

WATER TREATMENT PLANT AS-BUILT SHEET



PROFILE @ CENTER OF WATER TREATMENT POND DIKE


SCALE: VERT: 1"=4'-0"
HORIZ: 1"=40'-0"



PROFILE @ CENTER OF WATER TREATMENT POND DIKE

SCALE: (SAME AS ABOVE)

NOTE: ADD 20% SURCHARGE TO BORROW



PROFILE @ CENTER OF SPILLWAY

SCALE: VERT: 1"=5'-0"
HORIZ: 1"=20'-0"

NO.	DATE	REVISION	BY	CHKD	APPD	APPD	W.A.
1							

4 CORNERS POWER PLANT - NPDES
WATER TREATMENT POND DAM -
PROFILE @ CENTERLINE OF DAM

ARIZONA PUBLIC SERVICE COMPANY
PHOENIX

SCALE: AS NOTED DATE: JULY 31, 1978

APPROVED: *[Signature]* ENGINEERING MANAGER

DRAWING NO. G-67777

aecom.com