



Arizona Public Service Company
CCR Program
Environmental Policy & Programs

PO Box 53999
Mail Station 9303
Phoenix, AZ 85072-3999

Telephone: 602-250-1000

November 14, 2018

CCR Program Documentation
Groundwater Monitoring Program – Notification of Appendix IV Exceedances
FC_GW_AppIVExc_008_20181114
FC_GW_AppIVExc_011_20181114

Subject: GW – Notification of Appendix IV Exceedances; Four Corners Power Plant

Pursuant to 40 C.F.R. Secs 257.95(g), APS is providing notice that one or more constituents in Appendix IV are detected at statistically significant levels above the groundwater protection standard for the following units:

- LAI and North Toe Buttress/ Lined Decant Water Pond (Multi-Unit)
 - Cobalt; Molybdenum
- Upper Retention Pond
 - Fluoride

As such, APS will characterize the nature and extent of the release and any relevant site conditions that may affect the remedy ultimately selected.

If you have any questions about this or would like additional information, please consult the CCR information webpage located within APS.com or contact neal.brown@aps.com.

Per the September 8, 2015 letter to the Navajo Nation, this assessment monitoring notification should not be construed as a waiver of the covenant not to regulate contained in the site lease for the Four Corners Power Plant.